



SHRI GANESH TEST HOUSE

350, Baba Nagar, Meerut Road, Ghaziabad. (U.P.) 201001
E-mail : shriganesh_testhouse@yahoo.com
REGISTERED IN MSME, GOVT. OF INDIA.
AN ISO 9001 : 2015 CERTIFIED LAB.

TEST REPORT

REF. NO. SGTH/19-20/95

DATE - 19.06.2019

**M/S. NORTHERN INDIA PUBLIC SCHOOL,
211,212 JALAL PUR KALA,
GAJRAULA (AMROHA)
GOVERNED BY: B.R. FOUNDATION TRUST.**

1. ORDER NO. 57
2. DATE OF RECEIPT. 15.06.2019
3. DESCRIPTION. Water Sample
4. QUANTITY. Approx 1 Lit.
5. TEST REQUIRED. As Mentioned Below

S.NO.	TEST	RESULTS	REMARKS
1 -	<u>Physical:</u>		
i)	Appearance.	Clear.	As per these tests, submitted water sample is suitable for drinking purposes.
ii)	Odour.	Odourless.	
iii)	PH.	7.24	
2-	<u>Chemical:</u>		
i)	Total Chloride as Cl.	18.5 mg/lit.	
ii)	Total Alkalinity as CaCO ₃ .	280 mg/lit.	
iii)	Total Hardness as CaCO ₃ .	292 mg/lit.	
iv)	Temporary Hardness as CaCO ₃ .	72 mg/lit.	
v)	Permanent Hardness as CaCO ₃ .	220 mg/lit.	
vi)	Calcium as Ca.	72.5 mg/lit.	
vii)	Magnesium as Mg.	18.5 mg/lit.	
viii)	Dissolved Iron as Fe.	0.11 mg/lit.	
ix)	Dissolved Silica as SiO ₂ .	0.68 mg/lit.	
x)	Total Sulphate as SO ₄ .	44 mg/lit.	
xi)	Total Suspended Solid.	1.8 mg/lit.	
xii)	Total Dissolved Solid.	460 mg/lit.	

1. Sample (S) not collected by us unless otherwise specified.
2. Perishable samples will be destroyed after testing after 10 days.
3. The result listed above refer only to the tested samples.
4. Total liability is limited to the invoice amount only.
5. This report is not to be reproduced and can not be used as an evidence in the court of law without our permission in writing.

FOR SHRI GANESH TEST HOUSE


Manager/Director

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. NILDate : 15.07.2019

It is certified that an inspection team headed by Rekha Devi (Name of Officers with designation) from Pradhan Gram Panchayat Jalalpur Kalan Gajraula Amroha (Department/Office) inspected the Northern India Public School, NH-24, Gajraula on 15/July/2019 and found that the Northern India Public School, has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygiene & sanitation condition in the school building & the campus as per the norms prescribed by the State Govt.

The above valid for a period of Five Years.

Signature with Seal : रखी
प्रधानName : REKHA DEVIDesignation : Pradhan Gram Panchayat
Jalal Pur Kalan
Block Gajraula (Amroha)

To
Chairman
Northern India Public School
NH-24, Village Jalalpur Kalan
Gajraula.