

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. CNC Caghi | 121 | 2023
7 | 11 | 2023

Date : 7 | 11 | 2023

It is certified that an inspection team headed by Dr Yogen Singh (Name of Officers with designation) from CNC Caghi District Authority (Name of Department/Office) inspected the *Northern India Public School, NH-24, Gajraula* on 7 | 11 | 2023 and found that the *Northern India Public School*, (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the State Govt.

The above valid for a period of One year

Signature with Seal : Y

Name : चिकित्सी अधीक्षक

Designation : नामुस्वारकेन्द्र, गजरौला
(अमरसहा)

To
Chairman
Northern India Public School
NH-24, Village Jalalpur Kalan
Gajraula.



SRI GANESH ANALYTICAL LAB

AN ISO 9001 : 2008 CERTIFIED LAB (REGISTERED IN MSME : GOVT. OF INDIA)

1111, KRISHNA NAGAR, MEERUT ROAD, GHAZIABAD-201003 (U.P.), INDIA

E-mail: sri ganesh analytical lab@gmail.com Ph.: 0120-2712103, Mob: 9211842818, 9911702615

Our Ref. No. Date Your Ref. No. Dated

TEST REPORT

Ref No : SGAL/24-25/1192

Date: 27/04/2025

Northern India Public School
211 – 212, Jalalpur Kala,
Gajraula, Amroha, Uttar Pradesh
Governed by: B.R. Foundation Trust

1. Order No 1192
2. Date of Receipt 24/04/2025
3. Description One sample of R.O. Water
4. Quantity Approx. 1 ltr.
5. Test Required As mentioned below

S. No.	Tested Parameter	Acceptable Limit	Result	Remarks	
Physical Analysis					
1.	Appearance	Clear	Clear	As per the following tests conducted in accordance with IS: 10500-2012, the provided sample is suitable for usage in drinking purposes.	
2.	Odor	Odorless	Odorless		
3.	Total Solids (in mg/l)		92.40		
4.	Total Dissolved Solids (in mg/l)	Less than 500 ppm	89.00		
5.	Total Suspended Solids (in mg/l)		3.40		
6.	pH	6.50 – 8.50	7.24		
Chemical Analysis					
1.	Total Alkalinity (in mg/l)	Less than 250 ppm	41.89		
2.	Total Chlorides Content as Cl (in mg/l)	Less than 250 ppm	32.41		
3.	Total Sulphates Content as SO ₄ (in mg/l)	Less than 200 ppm	14.68		
4.	Total Iron Content as Fe (in mg/l)	Less than 0.3 ppm	0.02		
5.	Total Calcium Content as Ca (in mg/l)	Less than 75 ppm	14.39		
6.	Total Magnesium Content as Mg (in mg/l)	Less than 30 ppm	9.47		
7.	Total Nitrates as NO ₃ (in mg/l)	Less than 45 ppm	2.41		
8.	Total Hardness as CaCO ₃ (in mg/l)	Less than 200 ppm	77.68		
9.	Total Ammonia Content as NH ₃ (in mg/l)	Less than 0.5 ppm	Not Traceable		
10.	Total Silica Content as SiO ₂ (in mg/l)		0.02		

For SRI GANESH ANALYTICAL LAB

Manager

1. Sample(s) not collected by us unless otherwise specified.
2. Perishable samples will be destroyed after testing after 10 days.
3. The result listed above refer only to the tested samples.
4. Total liability is limited to the invoice amount only.
5. This report is not to be reproduced and cannot be used as evidence in the court of law without our permission in writing.